

Confined Space Safety Assessment



SECTION 1: Information					
Confined Space ID:	Manhole: Electrical		Developed By:	Tighe & Bond	
Asset ID:	CSSA-23		Origin Date:	July 2019	
Building:	Exterior – Various Locations		Revision #	0	
Entry Location:	Manhole Cover		Revision Date:	-	
Entry Purpose:	Repair and Maintenance				
SECTION 2: Confined Space Determination					
If needing to enter an enclosed space, indicate which of the following apply:				Yes	No
1. Is the space large enough and so configured that you can bodily enter and perform work?				X	
2. Does the space have limited or restricted means for entry or exit? (Would it be difficult to exit the space through a standard door, ramp, or OSHA-compliant stairs?)				X	
3. Is the space intended for continuous employee occupancy? (Is the space equipped with HVAC, desk, phone, lighting, or other typical comforts of continuous occupancy)					X
<p style="text-align: center;"><i>If you have checked <u>ANY</u> of the highlighted boxes, you <u>DO NOT</u> have a confined space. Otherwise, you have a Confined Space.</i></p>					
Does this space meet the definition of a Confined Space?				Yes	
SECTION 3: Assessment of Atmospheric Hazards					
Atmospheric Hazard	Actual or Potential Hazard?		Can it be Eliminated?		Means to Eliminate Atmospheric Hazard
	Y	N	Y	N	
Oxygen Deficiency		X			
Flammable Gas or Vapor		X			
H ₂ S (Hydrogen Sulfide)		X			
CO (Carbon Monoxide)		X			
Other Toxic Gas (Specify below):					
SECTION 4: Assessment of Serious Safety Hazards					
<i>Hazards which are immediately dangerous to life or health or would impair your ability to perform a self-rescue</i>					
Serious Safety Hazards	Actual or Potential Hazard?		Serious Safety Hazards	Actual or Potential Hazard?	
	Y	N		Y	N
Engulfment Hazard	X		Other Serious Safety Hazard		X
Trapping Hazard		X	Moving Parts or Agitator		X
Converging walls		X	Steam or Extreme heat/cold		X
Tapered floor		X	Shock or Electrocution	X	
Sloping floor		X	Other (Specify):		
Means to Eliminate Engulfment and Other Serious Safety Hazards			Pump out any pooled water prior to entry. Follow Hazardous Energy Isolation (Lockout/Tag-out) Procedures if working on electrical components.		
Means to Eliminate Trapping Hazards					
<p style="text-align: center;"><i>If you have <u>ONLY</u> checked shaded boxes in Section 3 and Section 4, you do not have a permit required confined space. Stop completing this form, and you may enter without a permit. Otherwise, continue completing this form.</i></p>					
Does this space meet the criteria for a non-Permit Confined Space?				No	

Confined Space Safety Assessment



SECTION 5: Assessment of Other Safety Hazards

Other Safety Hazards	Actual or Potential Hazard?		Can it be Eliminated?		Means to Eliminate Safety Hazard
	Y	N	Y	N	
Eye / Skin Hazard	X		X		Wear appropriate personal protective equipment to protect bare skin and eyes from electricity.
Mechanical Hazard		X			
Heat/Cold Stress		X			
Hot/Cold surfaces		X			
Space Configuration		X			
Egress / Access	X		X		Personnel are required to enter through the manhole opening. Use ladder for entry and egress.
Slippery Surfaces		X			
Elevated Work (Falls)		X			
Other (Specify below):		X			
Falling objects from above	X		X		Protect the space using barriers. Keep all tools and equipment away from the entrance space.

SECTION 6: Entry Classification

Reclassification Assessment	Yes	No
1. Is there an actual or potential atmospheric hazard (Section 3) – Even if controlled?		X
2. Can all Serious Safety Hazards (Section 4) be eliminated without entry?	X	
3. Can all Other Safety Hazards (Section 5) be eliminated without entry?	X	

If you have checked ONLY shaded boxes, you can reclassify the space as a non-permit required confined space. Stop completing this form, and you may enter without a permit.

Can this space be reclassified to a non-Permit Confined Space?

Yes

Permit Required Confined Space?

NA

Should any planned or unplanned activities or hazards occur which are not listed above, such as welding, cutting, chemical usage, etc. would require a reassessment of the of the space prior to entry.

SECTION 7: Photo(s)